

**ANDHRA PRADESH LEGISLATIVE COUNCIL
SESSION: 4**

**STARRED QUESTION No. 804
B. Kamalaker**

By Sri

Rao, MLC.

Will the Minister for Energy be pleased to state:

- a). The district-wise number of persons who lost their lives due to electrocution caused by faulty network including hanging wires and slanting electric poles;
- b). whether it is a fact that the amount sanctioned for repairs has not been fully utilized by the four DISCOMs;
- c). the details of the amounts approved by the Electricity Regulatory Authority to till date from the year 2003-04 together with the details of the amounts utilized by the four DISCOMs; and
- d). the measures being taken to see that basic guidelines with regard to safeguards are strictly followed by the four DISCOMs ?

**ENERGY (PR.IV) DEPARTMENT
ANSWER**

- a). Sir, the details are placed on the table of the House. (Statement - 1)
- b). No sir. The amounts spent by DISCOMs for repairs are more than the amounts approved by APERC.
- c). The details are placed on the table of the House. (Statement -2)
- d). Several safety measures like erection of intermediate poles/rectification of leaning poles, stringing of loose lines, providing of stays and guy insulators, replacement of DTR neutral wire/earth wire, replacement of damaged conductor etc. are being taken up regularly in campaign mode to avert electrical accidents by the DISCOMs.

(THE ABOVE ANSWER HAS BEEN APPROVED BY SRI MOHAMMED ALI SHABBER, MINISTER FOR ENERGY, COAL AND MINORITIES WELFARE)

for Spl. Chief Secretary to
Government.

To
The A.P. Legislative Council, Hyderabad. (200 copies).
The Spl. Secy. to Chief Minister (6 copies).
The Chairman & Managing Director, APTRANSCO /
APEPDCL / APSPDCL / APCPDCL / APNPDCL.

Copy to:

P.S. to Minister (Energy, Coal & M.W)
The P.S. to Spl. Chief Secy. to Govt., Energy.
The P.A. to Joint Secy. to Govt., Energy Department.
Energy (CCB) Dept.
The GA (L&C) Dept.
Sc/Sf.

(Energy Dept. U.O. Note No. 481/Pr.IV/2008-1, Dt: 25.03.2008)